



## Lifeline® MC: Two-Hour Fire Resistive Cables

Fire Resistive Cable for Survivability in a Fire



### Applications

Lifeline® MC fire resistive cables were designed to meet and have successfully passed the two-hour fire rating certification test per UL 2196, *Standard for Tests for Fire Resistive Cables*.

**Lifeline® MC Cables can be used in the following applications to provide survivability during a fire:**

- Tall Buildings
- Emergency Feeder Cables
- Stairwell Pressurization
- Elevators / OEO
- Emergency lighting for roadway and transit tunnels when cables include optional LSZH jacket over armor
- Fire Pumps
- Ventilating Fans
- Exit Lighting

Lifeline® MC Cables are preferred over Mineral Insulated (MI) cables, concrete encasement or the construction of fire rated assemblies based on the facts that Lifeline® MC Cables are less costly and easier to install for many applications.

Fire resistive cables are required per NFPA 70/NEC, Articles 517, 695, 700, 708, 728 and 760 as well as NFPA 72 and NFPA 101.



**RoHS**  
COMPLIANT

### Specifications and Ratings

- Listed to UL 1569, Metal Clad Cables, as the following type:
- Type MC 600 Volt, Rated 90°C
- For Wet Locations
- For Cable Tray Use IEEE 1202/ FT4 Rated, ST1 Limited Smoke
- Classified to UL 2196, Standard for Tests for Fire Resistive Cables, for two-hours installations
- Electrical Circuit Integrity System (FHIT) No. 50 of the UL Fire Resistance Directory
- NFPA 70, NFPA 101 compliant
- Corrugated Copper Armor meets Equipment Grounding Conductor requirements of NEC Table 250.122

### Design Parameters

**CONDUCTORS:** Bare stranded copper, 14 AWG through 600 kcmil

**INSULATION:** Ceramifiable Silicone Zero Halogen (LSZH)

**INNER BINDER JACKET:** Ceramifiable Silicone Zero Halogen (LSZH)

**ARMOR:** Continuously Welded and Corrugated Copper

#### IDENTIFICATION:

Lifeline® MC Unjacketed Cables are marked as follows: DRAKA MA P/N [#####] [X]/C [Y] LIFELINE (UL) E66840T MC-ST1 600V 90C WET LOCS FOR CT USE IEEE 1202/FT4 ST1 (UL) R19359 FRR 2HR UL 2196 ELECTRIC CIRCUIT INTEGRITY SYSTEM FHIT#50 480V UTILIZATION (MONTH/YEAR) (SEQUENTIAL FOOTAGE)

Notes: [#] is cable part number

[X] is the number of conductors

[Y] is the size of the cable in AWG or kcmil



A brand of the



## Lifeline® MC: Two-Hour Fire Resistive Cables

Fire Resistive Cable for Survivability in a Fire

### Lifeline® MC Power Cable

LIFELINE® Part Number	Conductor Size AWG /MCM	Number of Cond	Nominal Core Diameter (in)	Nominal Armor Diameter (in)	Ampacity 90°C Amps
LMC05014	14	5	0.66	0.97	25**
LMC02012	12	2	0.56	0.85	30**
LMC03012	12	3	0.59	0.91	30**
LMC04012	12	4	0.64	0.97	30**
LMC05012	12	5	0.70	0.97	30**
LMC02010	10	2	0.61	0.85	40**
LMC03010	10	3	0.64	0.97	40**
LMC04010	10	4	0.70	0.97	40**
LMC05010	10	5	0.77	1.08	40**
LMC02008	8	2	0.70	0.97	55
LMC03008	8	3	0.75	1.08	55
LMC04008	8	4	0.82	1.18	55
LMC05008	8	5	0.90	1.26	55
LMC02006	6	2	0.78	1.08	75
LMC03006	6	3	0.83	1.18	75
LMC04006	6	4	0.91	1.26	75
LMC05006	6	5	1.00	1.35	75
LMC03004	4	3	0.95	1.35	95
LMC04004	4	4	1.04	1.35	95
LMC05004	4	5	1.15	1.58	95
LMC03003	3	3	1.00	1.35	115
LMC04003	3	4	1.11	1.40	115
LMC03002	2	3	1.07	1.40	130
LMC04002	2	4	1.18	1.58	130
LMC03001	1	3	1.24	1.73	145
LMC04001	1	4	1.37	1.73	145
LMC031/0	1/0	3	1.33	1.73	170
LMC041/0	1/0	4	1.47	1.85	170
LMC032/0	2/0	3	1.41	1.85	195
LMC042/0	2/0	4	1.56	1.97	195
LMC033/0	3/0	3	1.52	1.97	225
LMC043/0	3/0	4	1.69	2.15	225
LMC034/0	4/0	3	1.64	2.15	260
LMC044/0	4/0	4	1.82	2.28	260
LMC03250	250	3	1.81	2.28	290
LMC04250	250	4	2.00	2.52	290
LMC03350	350	3	2.04	2.52	350
LMC04350	350	4	2.26	2.72	350
LMC03400	400	3	2.13	2.72	380
LMC04400	400	4	2.37	2.83	380
LMC03500	500	3	2.31	2.83	430
LMC04500	500	4	2.57	3.11	430
LMC03600	600	3	2.54	3.11	475
LMC04600	600	4	2.83	3.41	475

\*Ampacities are based on Table 310.15(B)(16) of the National Electrical Code (NEC) (NFPA 70-2017) for 3 current carrying conductors at 30°C ambient.

\*\*Small overcurrent protection limitations per NEC Article 240.4(D): (3) 14AWG – 15amps, (5) 12AWG – 20amps, (7) 10AWG – 30amps

The above dimensions are approximate and subject to normal manufacturing tolerances. Information subject to change

© DRAKA - A Brand of The Prysmian Group. 2018 All Rights Reserved. The information contained within this document must not be copied, reprinted or reproduced in any form, either wholly or in part, without the written consent of Prysmian Group. The information is believed correct at the time of issue. Prysmian Group reserves the right to amend any specifications without notice. These specifications are not contractually valid unless authorized by Prysmian Group. Issued April 2018.

**Prysmian Group**  
 700 Industrial Drive | Lexington, SC 29072 | website: [na.prysmiangroup.com/lifeline](http://na.prysmiangroup.com/lifeline)  
**Sales and Distribution:**  
 22 Joseph E. Warner Blvd. | North Dighton, MA 02764 | +1-508-822-5444

LIFELINE\_MC\_2-HOUR\_2018-04-03